



CERTIFICATE FI 28311

Our Ref. 271847-2

Product XLPE-insulated power cable

Type AXMK

Trade mark ENERGOCOMPLEKT

**Certificate Holder/
Manufacturer** Energocomplekt Co., Ltd.
Vitebsk, Moskovsky av., 94B
210035, BELARUS

Technical information Number and nominal cross-sectional area of conductors:
AXMK 1x35-1000 mm²
4(5)x16-300 mm²
XMK 1x35-800 mm²

Other information Rated voltage 0,6/1 kV
See the Appendix to this Certificate

The product is certified according to the following standard(s) HD 603 S1:1994 + A1:1997 + A2:2003 + A3:2007 Part 5 Section D
SFS 4879:2008

Validity This certificate is valid until 22 November 2018 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue 22 November 2013

Signature **SGS Fimko Ltd**



Sixten Lökfors
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkiniementie 3 P.O.Box 30 FI-00211 Helsinki, Finland
t. +358 9 696 361 f. +358 9 692 5474 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Appendix to Certificate: 28311

Manufacturing site

Energocomplekt Co., Ltd.
Vitebsk, Moskovsky av., 94B
210035, BELARUS

Additional information

This certificate applies also to non standard number of conductors:
AXMK 5x16-300 mm²

Test Reports:

AXMK 4x25 - 271847-2a

AXMK 5x16 - 271847-2b

XMK 1x240 - 271847-2c

Reference No. STR 1496

Our ref.
271847-2

Place and date
Helsinki 22 November 2013



STATEMENT OF TEST RESULTS

Product	XLPE-insulated power cable
Tested on request of	Energocomplekt Co., Ltd. Vitebsk, Moskovsky av., 94B 210035, BELARUS
Name and address of the manufacturer	Energocomplekt Co., Ltd. Vitebsk, Moskovsky av., 94B 210035, BELARUS
Name and address of the factory	Energocomplekt Co., Ltd. Vitebsk, Moskovsky av., 94B 210035, BELARUS
Rating and principal characteristics	Number and nominal cross-sectional area of conductors: AXMK 1x35-1000 mm ² 4x16-300 mm ² 5x16-300 mm ² XMK 1x35-800 mm ²
Trade mark (if any)	ENERGOCOMPLEKT
Type	AXMK and XMK
Additional information (if any)	Rated voltage 0,6/1 kV
Sufficient samples of the product have been tested and found to be in conformity with the current standard (number and edition)	IEC 60502-1:2004 (Ed 2) + A1:2009
As shown in the test report (reference No.)	271847-2, 271847-3 and 271847-4

This statement has been established by a body notified to the Member States and Commission of the European Communities according to the provisions of Article 11 of the Low Voltage Directive of 12 December 2006.

This statement of test results is the result of testing samples of the product and verifying the testing documentation in accordance with the provisions of the relevant specific standards and the Low Voltage Directive (2006/95/EC). It does not imply an assessment of the whole production, technical documentation or fulfilment of other additional requirements in the Directive. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the directive are fulfilled.

This statement of test results is not an FI certificate thus not giving the right to use the FI or SGS FI mark on products, its packaging or any marketing material or activities.

SGS Fimko Ltd  Sixten Lökfors Project Manager	 The form of the CE marking
--	--

This document is issued by the company under its General Conditions of Service accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd. | Särkiniementie 3, P.O.Box 30 FI-00211 Helsinki, Finland
t. +358 9 696 361 f. +358 9 692 5474 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)